



Application for Licence Amendment

Part V Division 3 of the *Environmental Protection Act 1986*

Licence Number	L4201/1991/11
Licence Holder	Water Corporation
ACN	634 169 841
File Number	DEC6295/3
Premises	Woodman Point Water Resource Recovery Facility Lot 9 Cockburn Road MUNSTER WA 6166 Legal description - Being part of Lot 9 on Diagram 31097 As defined by the coordinates in Schedule 2
Date of Report	26 June 2023
Decision	Revised licence granted

Sarah Cross

**A/SENIOR ENVIRONMENTAL OFFICER
INDUSTRY REGULATION**

an officer delegated under section 20 of the *Environmental Protection Act 1986* (WA)

Table of Contents

1. Decision summary	3
2. Scope of assessment	3
2.1 Regulatory framework	3
2.2 Application summary	3
3. Consultation	3
4. Conclusion	3
4.1 Summary of amendments.....	4
References	4

1. Decision summary

Licence L4201/1991/11 is held by the Water Corporation (Licence Holder) for the Woodman Point water resource recovery facility (the Premises), located at Lot 9 Cockburn Road, MUNSTER WA.

The Delegated Officer has determined to make amendments to Licence L4201/1991/11. The amendments outlined within this amendment report do not alter the risk profile of the Premises. As a result of this assessment, Revised Licence L4201/1991/11 has been granted.

This Amendment Report documents the amendments made pursuant to section 59 and 59(B) of the *Environmental Protection Act 1986* (EP Act).

The Revised Licence issued as a result of this amendment consolidates and supersedes the existing Licence previously granted in relation to the Premises. The Revised Licence has been granted in a new format with existing conditions being transferred, but not reassessed, to the new format.

The Amendment Report for the Existing Licence will remain on the department's website for future reference and will act as a record of the department's decision making.

2. Scope of assessment

2.1 Regulatory framework

In amending the licence, the department has considered and given due regard to its Regulatory Framework and relevant policy documents which are available at <https://dwer.wa.gov.au/regulatory-documents>.

2.2 Application summary

On 13 March 2023, the Licence Holder submitted an application to the department to amend Licence L4201/1991/11 under section 59 and 59B of the *Environmental Protection Act 1986* (EP Act). The amendment is limited only to altering the due date for the environmental report and annual audit compliance report, to be 1 October annually.

No changes to the aspects of the Existing Licence relating to Category 54 and Category 61 have been requested by the Licence Holder. Table 1 below outlines the current approved production/design capacity for the Premises.

Category	Approved design capacity
Category 54 Sewage facility: premises — (a) on which sewage is treated (excluding septic tanks); or (b) from which treated sewage is discharged onto land or into waters.	180,000 m ³ per day
Category 61: Liquid waste facility: premises on which liquid waste produced on other premises (other than sewerage waste) is stored, reprocessed, treated or irrigated.	50,000 tonnes per annual period

3. Consultation

The Licence Holder was provided with the draft Amendment Report on 12 May 2023. Comments received from the Licence Holder on 1 June 2023 requested to change the premises name to Woodman Point Water Resource Recovery Facility. This amendment has been incorporated into the final instrument.

4. Conclusion

Based on the assessment in this Amendment Report, the Delegated Officer has determined that a Revised Licence will be granted, subject to conditions commensurate with the determined controls and necessary for administration and reporting requirements.

4.1 Summary of amendments

Table 2 below provides a summary of the proposed amendments and will act as a record of implemented changes. All proposed changes have been incorporated into the Revised Licence as part of the amendment process.

Table 1: Summary of licence amendments

Condition no.	Proposed amendments
Cover page	Corrected ACN Updated the registered business address and premises name to be 'Woodman Point Water Resource Recovery Facility'
History	Updated history of the licence
Throughout	Condition wording updated to current template format: "shall" replaced with "must".
Condition 1	Condition considered redundant, so amended to current licensing format.
Condition 7 Table 2	Units used in Quantity limit altered to m ³ for clarification of condition requirements.
Condition 9 Table 3	Units used in process requirements altered to m ³ , acronyms expanded and the phrase "and" added to biosolids process, for clarification of condition requirements.
Condition 24 Table 10	Units used for contaminant loading expanded to kg/day for clarification of condition requirements.
Condition 25 Table 11	Continuous frequency of monitoring wastewater output included and acronyms expanded for clarification of condition requirements.
Condition 29	Condition reworded and updated to change the AACR reporting submission date as requested by the Licence Holder.
Condition 31 Table 13	Condition reworded and updated to change the AER reporting submission date as requested by the Licence Holder.
Condition 31	Removal of the word "Annual" for clarification of condition requirements.
Condition 32	Condition 32 (a) considered redundant so amended to current licensing format.
Condition 34 Table 15	Acronyms expanded for clarification of condition requirements.
Definitions Table 16	Definitions added: 'approved form' and 'condition'
N/A	'Licensee' reworded to 'licence holder'. 'Shall' reworded to 'must'. Acronyms expanded for clarity.

References

1. Department of Environment Regulation (DER) 2015, Guidance Statement: Setting Conditions, Perth, Western Australia.
2. Department of Water and Environmental Regulation (DWER) 2020, Guideline: Environmental Siting, Perth, Western Australia.
3. DWER 2020, Guideline: Risk Assessments, Perth, Western Australia.