



Annual Audit Compliance Report Form

Environmental Protection Act 1986, Part V Division 3

Once completed, please submit this form either via email to info@dwer.wa.gov.au, or to the below postal address:

Department of Water and Environmental Regulation
Locked Bag 10
Joondalup DC WA 6919

Section A – Licence details			
Licence number:	L6320/1991/8	Licence file number:	DER2014/000605
Licence holder name:	Water Corporation		
Trading as:	Gnowangerup Wastewater Treatment Plant		
ABN:	28 003 434 917		
Registered business address:	629 Newcastle Street, LEEDERVILLE, WA 600		
Reporting period:	01/07/2024 to 30/06/2025		

Section B – Statement of compliance with licence conditions
Did you comply with all of your licence conditions during the reporting period? (please tick the appropriate box)
<input type="checkbox"/> Yes – please complete: <ul style="list-style-type: none">• section C;• section D (if required); and• sign the declaration in Section F.
<input checked="" type="checkbox"/> No – please complete: <ul style="list-style-type: none">• section C;• section D (if required);• section E; and• sign the declaration in Section F.

Section C – Statement of actual production	
Provide the actual production quantity for this reporting period. Supporting documentation is to be attached.	
Prescribed premises category	Actual production quantity
54	92 m ³ /day


Section D – Statement of actual Part 2 waste discharge quantity	
Provide the actual Part 2 waste discharge quantity for this reporting period. Supporting documentation is to be attached.	
Prescribed premises category	Actual Part 2 waste discharge quantity

Section E – Details of non-compliance with licence condition			
Please use a separate page for each condition with which the licence holder was non-compliant at a time during the reporting period.			
Condition no:	2.3.1	Date(s) of non-compliance:	2024/25 reporting period
Details of non-compliance:			
Condition 2.3.1 requires the continuous monitoring of the discharge volume of wastewater to emission point L1. The monitoring unit was malfunctioning between during the 2024/25 reporting period and not recording flow volumes accurately.			
What was the actual (or suspected) environmental impact of the non-compliance? NOTE – please attach maps or diagrams to provide insight into the precise location of where the non-compliance took place.			
No environmental impact			
Cause (or suspected cause) of non-compliance:			
Solar charging unit battery failure.			
Action taken to mitigate any adverse effects of non-compliance and prevent recurrence of the non-compliance:			
New battery unit installed and meter operating normally.			
Was this non-compliance previously reported to DWER?			
<input type="checkbox"/> Yes, and		<input checked="" type="checkbox"/> No	
<input type="checkbox"/> Reported to DWER verbally	Date: / /		
<input type="checkbox"/> Reported to DWER in writing	Date: / /		

Section F – Declaration

I / We declare that the information in this Annual Audit Compliance Report is true and correct and is not false or misleading in a material particular¹.

I / We consent to the Annual Audit Compliance Report being published on the Department of Water and Environmental Regulation’s (DWER) website.



Date:	26 September 2025	Date:	
Seal (if signing under seal):			

¹ It is an offence under section 112 of the *Environmental Protection Act 1986* for a person to give information on this form that to their knowledge is false or misleading in a material particular.

² AACRs can only be signed by the licence holder or an authorised person with the legal authority to sign on behalf of the licence holder.