



Annual Audit Compliance Report Form

Environmental Protection Act 1986, Part V

Section A – Licence Details			
Licence number:	L6748/1994/13	Licence file number:	2011/003323-1
Licence holder:	Water Corporation		
Trading as:	Caddadup Water Resource Recovery Facility		
ACN:	28 033 434 917		
Registered address:	629 Newcastle Street, LEEDERVILLE, WA 6007		
Reporting period:	01 / 07 / 2022 to 30 / 06 / 2023		



Section B – Statement of Compliance with Licence Conditions
Did you comply with all of your licence conditions during the reporting period? (please tick the appropriate box)
<input type="checkbox"/> Yes – please complete: <ul style="list-style-type: none">• section C;• section D if required; and• sign the declaration in Section F.
<input checked="" type="checkbox"/> No – please complete: <ul style="list-style-type: none">• section C;• section D if required;• section E; and• sign the declaration at Section F.

Section C – Statement of Actual Production	
Provide the actual production quantity for this reporting period. Supporting documentation is to be attached.	
Prescribed Premises Category	Actual Production Quantity
54 – sewage facility	2,208 m ³ /d (details in Annual Environmental Report)

Section D – Statement of Actual Part 2 Waste Discharge Quantity	
Provide the actual Part 2 waste discharge quantity for this reporting period. Supporting documentation is to be attached.	
Prescribed Premises Category	Actual Part 2 Waste Discharge Quantity

Section E – Details of Non-Compliance with Licence Condition			
Please use a separate page for each condition with which the licence holder was non-compliant at a time during the reporting period.			
Condition no:	1.3.4	Date(s) of non-compliance:	17/12/2021; 01/06/2022
Details of non-compliance:			
<p>Inlet works are compliant with the requirements of condition 1.3.3 however, are non-compliant with the requirements of condition 1.3.4. Condition 1.3.4 requires the hardstand area to be bunded.</p> <p>There is a hardstand underneath the grit & screening bin is graded and allows collection of leachate, where it is returned to the bioselector. However, the hardstand area is not bunded.</p>			
What was the actual (or suspected) environmental impact of the non-compliance?			
<p>NOTE – please attach maps or diagrams to provide insight into the precise location of where the non-compliance took place.</p> <p>Grit and screens are located on a hardstand area that drains to a sump, which returns any leachate to the to the bioselector. The lack of bunding at the entrance to this area does not pose any additional risk of spills or overflows to the environment; therefore there is no suspected or actual environmental impacts.</p>			
Cause (or suspected cause) of non-compliance:			
<p>Grit and screenings bins are located on a graded hardstand area. Leachate is primarily contained in the bins, however should any surplus leachate escape the area drains to a sump, which drains to the return liquor pump station. From here leachate is returned to the bioselector, immediately downstream of the inlet works at the head of the plant. It was determined at design stage that this was an acceptable mitigation of any environmental risks, therefore bunding was not installed.</p>			
Action taken to mitigate any adverse effects of non-compliance and prevent recurrence of the non-compliance:			
<p>An amendment to remove this reference was requested as part of AER/AACR Due Date Amendment Program – Omnibus Package 01: Additional Administrative Amendments Request A (30 June 2023). This amendment was approved by DWER to reflect this and the new licence should be issued by end of September 2023.</p>			
Was this non-compliance previously reported to DWER? Yes			
<input checked="" type="checkbox"/> Yes, and			
<input type="checkbox"/> Reported to DWER verbally		Date: / /	
<input checked="" type="checkbox"/> Reported to DWER in writing		Date: 01 / 10 / 2022 (AACR)	

Section F – Declaration

<p>I / We declare that the information in this Annual Audit Compliance Report is true and correct and is not false or misleading in a material particular¹.</p> <p>I / We consent to the Annual Audit Compliance Report being published on the Department of Water and Environmental Regulation's (DWER) website.</p>			
Signature ² :		Signature:	
Name: (printed)		Name: (printed)	
Position:	General Manager Operations	Position:	
Date:	13 SEPT 2023	Date:	
Seal (if signing under seal):			

¹ It is an offence under section 112 of the *Environmental Protection Act 1986* for a person to give information on this form that to their knowledge is false or misleading in a material particular.

² AACRs can only be signed by the licence holder or an authorised person with the legal authority to sign on behalf of the licence holder.