

Government of Western Australia Department of Water and Environmental Regulation

Annual Audit Compliance Report Form

Environmental Protection Act 1986, Part V

Section A – Licence Details			
Licence number:	L7685/1993/6	Licence file number:	2010/002604
Licence holder:	Water Corporation		
Trading as:	Dongara Wastewater Treatment Plant		
ABN:	28 003 434 917		
Registered address:	629 Newcastle Street, LEEDERVILLE, WA 6007		
Reporting period:	01/07/2022 to 30/06/2023		

Section B - Statement of Compliance with Licence Conditions

Did you comply with all of your licence conditions during the reporting period? (please tick the appropriate box)

☐Yes – please complete:

- section C;
- · section D if required; and
- sign the declaration in Section F.

⊠No – please complete:

- section C;
- · section D if required;
- · section E; and
- · sign the declaration at Section F.

Section C – Statement of Actual Production

Provide the actual production quantity for this reporting period. Supporting documentation is to be attached.

Prescribed Premises Category	Actual Production Quantity	
54	Inflow estimated 410 m³/day	

Section D – Statement of Actual Part 2 Waste Discharge Quantity

Provide the actual Part 2 waste discharge quantity for this reporting period. Supporting documentation is to be attached.

Prescribed Premises Category	Actual Part 2 Waste Discharge Quantity	
Not Applicable		


Section E – Details of Non-Compliance with Licence Condition


Please use a separate page for each condition with which the licence holder was non-compliant at a time during the reporting period.

Condition no: 1.3.5 (e) Date(s) of non-compliance: 19/06/2023

Details of non-compliance: (INC-069546_2023)

An increase in Total Nitrogen in bore 3/95 (since 2012) and in 4/95 (since 2019). No increase in TN upstream.





What was the actual (or suspected) environmental impact of the non-compliance?

NOTE – please attach maps or diagrams to provide insight into the precise location of where the non-compliance took place.

ERA investigation noted the risk of seepage to receptors was low however there is still a data gap associated with the undelineated extent of impacts.

Cause (or suspected cause) of non-compliance:

Department of Water and Environmental Regulation

A preliminary water balance indicates potent	ial leakage from treatment ponds.
Action taken to mitigate any adverse effects non-compliance:	of non-compliance and prevent recurrence of the
the pond is identified it will be isolated and real An Asset Deficiency Record (ADR) (25668) I August 2023 review determined the need to	has been entered for the Dongara WWTP. An further assess data if dumping of filter backwash he possible reason for the increasing nitrate levels.
Was this non-compliance previously reported	d to DWER?
☐ Yes, and	☑ No
☐ Reported to DWER verbally	Date:
Reported to DWER in writing (N1 Notification)	Date: 18/07/2022

Section F - Declaration

I/We declare that the information in this Annual Audit Compliance Report is true and correct and is not false or misleading in a material particular¹. I/We consent to the Annual Audit Compliance Report being published on the Department of Water and Environmental Regulation's (DWER) website.

Signature ² :		Signature:
Name: (printed)		Name: (printed)
Position:	General Manager Operations Group	Position:
Date:	15 SEPT 2023	Date:
Seal (if signing under seal):		

¹ It is an offence under section 112 of the *Environmental Protection Act 1986* for a person to give information on this form that to their knowledge is false or misleading in a material particular.

² AACRs can only be signed by the licence holder or an authorised person with the legal authority to sign on behalf of the licence holder.