



Works Approval

Works approval number	W2881/2025/1
Works approval holder	Chevron Australia Pty Ltd
ACN	086 197 757
Registered business address	Level 1 162 Grand Boulevard JOONDALUP WA 6027
DWER file number	APP-0026281 / DER2019/000441~13
Duration	18/11/2025 to 17/11/2028
Date of issue	18 November 2025
Premises details	Wheatstone LNG Project Legal description - Part Lot 567 on Deposited Plan 71345 Certificate of Title Volume 2779 Folio 361 As defined by the Premises Map in Schedule 2 – Figure 1

Prescribed premises category description (Schedule 1, <i>Environmental Protection Regulations 1987</i>)	Assessed production / design capacity
Category 34: Oil or gas refining - premises on which crude oil, condensate or gas is refined or processed.	LNG: 12 million tonnes per annual period Condensate: 1.1 million tonnes per annual period

This works approval is granted to the works approval holder, subject to the attached conditions, on 18 November 2025, by:

Melissa Chamberlain
MANAGER, PROCESS INDUSTRIES

an officer delegated under section 20 of the *Environmental Protection Act 1986* (WA)

Works approval history

Date	Reference number	Summary of changes
18/11/2025	W2881/2025/1	Works approval granted.

Interpretation

In this works approval:

- (a) the words ‘including’, ‘includes’ and ‘include’ in conditions mean “including but not limited to”, and similar, as appropriate;
- (b) where any word or phrase is given a defined meaning, any other part of speech or other grammatical form of that word or phrase has a corresponding meaning;
- (c) where tables are used in a condition, each row in a table constitutes a separate condition;
- (d) any reference to an Australian or other standard, guideline, or code of practice in this works approval:
 - (i) if dated, refers to that particular version; and
 - (ii) if not dated, refers to the latest version and therefore may be subject to change over time;
- (e) unless specified otherwise, any reference to a section of an Act refers to that section of the EP Act; and
- (f) unless specified otherwise, all definitions are in accordance with the EP Act.

NOTE: This works approval requires specific conditions to be met but does not provide any implied authorisation for other emissions, discharges, or activities not specified in this works approval.

Works approval conditions

The works approval holder must ensure that the following conditions are complied with:

Construction phase

Infrastructure and equipment

1. The works approval holder must:
 - (a) construct and/or install the infrastructure and/or equipment;
 - (b) in accordance with the corresponding design and construction / installation requirements; and
 - (c) at the corresponding infrastructure location; and
 as set out in Table 1.

Table 1: Design and construction / installation requirements

Infrastructure	Design and construction / installation requirements	Infrastructure location
Process gas tie-ins: - One DN900 isolation valve and spool with reducer tied into existing infrastructure - A new DN750 flanged (blind) pipework not tied into existing infrastructure (preserved with Nitrogen)	(i) Tie-in installation works must be undertaken while the LNG trains are shut down, isolated and purged of residual gas to minimize gaseous emissions to air.	Areas labelled 'Process vent gas tie-in (T1)' and 'Process vent gas tie-in (T2)' in Figure 3, Schedule 1
Fuel gas tie-ins: - One DN 100 spool and double block and bleed isolation valves and flanged (blind, with no preservation) - Provision for installation of a DN25 low point drain and double block and bleed isolation valves.		Areas labelled 'Fuel gas gas tie-in (T1)' and 'Fuel gas tie-in (T2)' in Figure 3, Schedule 1
Firewater tie-ins: - Demolition of OD 350 Line and manual firewater monitor - Relocation of a firewater monitor - Re-orientation of existing firewater monitor - Addition of a firewater monitor - Demolition and re-routing of OD630 firewater line (Train 2 only)	(ii) New fire-water lines installed must be hydrotested to prevent leakage of potentially contaminated water.	Areas labelled 'Firewater tie-in for Reroute (T1)' and 'Firewater tie-in for Reroute (T2)' in Figure 3, Schedule 1
Concrete pads for thermal oxidizer package	(iii) Must be concreted and graded to drain towards the existing stormwater drainage infrastructure.	Areas labelled 'Foundation – Soil excavation (T1)' and 'Foundation – Soil excavation (T2)' in Figure 3, Schedule 1

Compliance reporting

- The works approval holder must within 30 calendar days of an item of infrastructure or equipment required by condition 1 being constructed and/or installed:

- (a) undertake an audit of their compliance with the requirements of condition 1; and
 - (b) prepare and submit to the CEO an Environmental Compliance Report on that compliance.
3. The Environmental Compliance Report required by condition 1, must include as a minimum the following:
- (a) certification by a representative of the works approval holder that the items of infrastructure or component(s) thereof, as specified in condition 1, have been constructed in accordance with the relevant requirements specified in condition 1;
 - (b) be signed by a person authorised to represent the works approval holder and contains the printed name and position of that person.

Minimum requirements during construction

4. The works approval holder must undertake the minimum requirements specified in Table 2 for the works to minimise emissions and discharges from the premises.

Table 2: Minimum requirements during construction/installation

Controls	Requirements
Management of excavated soils	(a) Excavated soil materials shall be solely reused within the activity disturbance footprint or stored in enclosed containers prior to disposal at an appropriately authorised facility.

Records and reporting (general)

5. The works approval holder must record the following information in relation to complaints received by the works approval holder (whether received directly from a complainant or forwarded to them by the Department or another party) about any alleged emissions from the premises:
- (a) the name and contact details of the complainant, (if provided);
 - (b) the time and date of the complaint;
 - (c) the complete details of the complaint and any other concerns or other issues raised; and
 - (d) the complete details and dates of any action taken by the works approval holder to investigate or respond to any complaint.
6. The works approval holder must maintain accurate and auditable books including the following records, information, reports, and data required by this works approval:
- (a) the works conducted in accordance with condition 1;
 - (b) any maintenance of infrastructure that is performed in the course of complying with condition 1;
 - and
 - (c) complaints received under condition 5.

- 7.** The books specified under condition 6 must:
- (a) be legible;
 - (b) if amended, be amended in such a way that the original version(s) and any subsequent amendments remain legible and are capable of retrieval;
 - (c) be retained by the works approval holder for the duration of the works approval; and
 - (d) be available to be produced to an inspector or the CEO as required.

Definitions

In this works approval, the terms in Table 3 have the meanings defined.

Table 3: Definitions

Term	Definition
books	has the same meaning given to that term under the EP Act.
CEO	means Chief Executive Officer. CEO for the purposes of notification means: Director General Department administering the <i>Environmental Protection Act 1986</i> Locked Bag 10 Joondalup DC WA 6919 info@dwer.wa.gov.au
Department	means the department established under section 35 of the <i>Public Sector Management Act 1994</i> and designated as responsible for the administration of Part V Division 3 of the EP Act.
discharge	has the same meaning given to that term under the EP Act.
DN	Diametre Nominal
emission	has the same meaning given to that term under the EP Act.
Environmental Compliance Report	means a report to satisfy the CEO that the conditioned infrastructure and/or equipment has been constructed and/or installed in accordance with the works approval.
EP Act	<i>Environmental Protection Act 1986 (WA)</i> .
EP Regulations	<i>Environmental Protection Regulations 1987 (WA)</i> .
premises	the premises to which this licence applies, as specified at the front of this licence and as shown on the premises map (Figure 1) in Schedule 1 to this works approval.
prescribed premises	has the same meaning given to that term under the EP Act.
waste	has the same meaning given to that term under the EP Act.
works approval	refers to this document, which evidences the grant of the works approval by the CEO under section 54 of the EP Act, subject to the conditions.
works approval holder	refers to the occupier of the premises being the person to whom this works approval has been granted, as specified at the front of this works approval.

END OF CONDITIONS

Schedule 1: Maps

Premises map

The boundary of the prescribed premises is shown in the map below (Figure 1).




Figure 1: Map showing the works approval premises boundary




Figure 2: Map showing the relevant infrastructure and equipment

W2881/2025/1




Figure 3: Map showing the premises emission and discharge point